



## ACORN METAL HALIDE (MH) LUMINAIRE

### SELECTION TABLE

PHOTOMETRIC/IES FILE (SEE NOTE 1)	IES LIGHT DISTRIBUTION CLASSIFICATION	LAMP WATTAGE	INITIAL LUMENS, TYPICAL (SEE NOTE 2)
-	TYPE III	70 W	5,600
CG267P	TYPE III	100 W	9,000
-	TYPE III	150 W	14,000

BOM LEGEND	
	ACORN LUMINAIRE WATTAGE
A	70 W
B	100 W
C	150 W

### BILL OF MATERIALS FOR 30-1120

ITEM NO.	DESCRIPTION	ITEM I.D.	QUANTITY		
			A	B	C
1	ACORN LUMINAIRE 120 V 70 W MH IES TYPE III MEDIUM E26 BASE	7900415	1	-	-
2	ACORN LUMINAIRE 120 V 100 W MH IES TYPE III MEDIUM E26 BASE	7900421	-	1	-
3	ACORN LUMINAIRE 120 V 150 W MH IES TYPE III MEDIUM E26 BASE	7900432	-	-	1
4	LAMP 70 W MH PULSE START ANSI M98/E MEDIUM E26 BASE CLEAR FINISH	8040011	1	-	-
5	LAMP 100 W MH PULSE START ANSI M90/E MEDIUM E26 BASE CLEAR FINISH	8040012	-	1	-
6	LAMP 150 W MH PULSE START ANSI M102/E MEDIUM E26 BASE CLEAR FINISH	8040013	-	-	1
* 7	PHOTOELECTRIC CONTROL N/C 120 V 1000 W 1.0 FC TURN-ON	7900525	1	1	1

\* IF SHORTING CAP IS REQUIRED, USE ITEM I.D. 7900540 INSTEAD OF ITEM 7.

#### NOTES:

- 1) IES FILE CG267P IS BASED ON 100 W LUMINAIRE. FOR 70 W AND 150 W, ADJUST THE LAMP LUMENS AS PER CORRESPONDING LAMP DATA.
- 2) FOR PRODUCT SPECIFIC LUMEN VALUES, REFER TO MANUFACTURER'S LAMP SPECIFICATION.

DISTRIBUTION CONSTRUCTION STANDARD  
Street Lighting

## ACORN LUMINAIRE

### SELECTION TABLE



Approved By:  
E.H. 2016-07-28

Drafted By:  
M.S.

Designed By:  
E.H.

Original Issue:

Scale:  
N.T.S.

Rev:

0

30-1120

1/1